

CR-5-1-CRM-BF-F-29	Conference Room Men's Restroom Sink Faucet	03/30/2023	0.0026		mg/L	0.0020
CR-5-1-CRW-BF-P-30	Conference Room Women's Restroom Sink Faucet	03/30/2023	0.0014	J	mg/L	0.0020
CR-5-1-CRW-BF-F-30	Conference Room Women's Restroom Sink Faucet	03/30/2023	0.0020	U	mg/L	0.0020
CR-5-2-206-DWC-P-31	Second Floor Water Fountain w/Cooler Room 206	03/30/2023	0.00099	J	mg/L	0.0020
CR-5-2-206-DWC-SS-31	Second Floor Water Fountain w/Cooler Room 206	03/30/2023	0.0024		mg/L	0.0020
CR-5-2-206-DWC-F-31	Second Floor Water Fountain w/Cooler Room 206	03/30/2023	0.0025		mg/L	0.0020
CR-5-2-208-BF-P-32	Room 208 Bathroom Sink Faucet	03/30/2023	0.024		mg/L	0.0010
CR-5-2-208-BF-F-32	Room 208 Bathroom Sink Faucet	03/30/2023	0.00074	J	mg/L	0.0020
CR-5-2-208-DW-P-33	Room 308 Water Fountain	03/30/2023	0.012		mg/L	0.0020
CR-5-2-208-DW-SS-33	Room 308 Water Fountain	03/30/2023	0.0029		mg/L	0.0020
CR-5-2-208-DW-F-33	Room 308 Water Fountain	03/30/2023	0.0022		mg/L	0.0020
CR-5-2-214-BF-P-34	Room 214 Bathroom Faucet	03/30/2023	0.0080		mg/L	0.0020
CR-5-2-214-BF-F-34	Room 214 Bathroom Faucet	03/30/2023	0.0024		mg/L	0.0020
CR-5-2-214-DW-P-35	Room 214 Water Fountain	03/30/2023	0.018		mg/L	0.0020
CR-5-2-214-DW-SS-35	Room 214 Water Fountain	03/30/2023	0.012		mg/L	0.0020
CR-5-2-214-DW-F-35	Room 214 Water Fountain	03/30/2023	0.0022		mg/L	0.0020

NA
NA
NA
NA
NA
NA
NA
Shut off/disconnect outlet, Post *Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample
NA
Shut off/disconnect outlet, Post *Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample
NA
NA
Shut off/disconnect outlet, Post *Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample
NA
Shut off/disconnect outlet, Post *Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample
Shut off/disconnect outlet, Post *Not for Drinking/Cooking at outlet, Provide Filters at Problem Tap, Continuous Daily/Weekly Flushing, Provide Bottle Water, Resample
NA

NA
NA
NA
NA
NA
NA
Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
NA
Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
NA
Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
NA
Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
Follow Immediate Remedial Response and Resample. If High Levels Remain follow the Long-Term Remedial Response: Provide Filters, Replace Problem Outlet, Replace Pipe, Reconfigure Plumbing, Resample
NA

Key - Sample Name	
P	Primary Sample
SS	Sequential Sample
F	Flush Sample

Key - Qualifier	
U	Not Detected in Laboratory Analysis
J	Result is Between Laboratory Detection Limit & Laboratory Reporting Limit